



THE YORK CENTRE ANNUAL DRINKING WATER REPORT

Drinking-Water System Number:	260008684
Drinking-Water System Name:	The York Centre Well Supply
Drinking-Water System Owner:	The York Centre for Children/Youth and Families
Drinking-Water System Category:	Small Non-Municipal Non-Residential
Period being reported:	March 2015-March 2016

On July 21st 2014 THE YORK CENTRE WELL SUPPLY completed an inspection by the Ministry of the Environment.
Inspection Number: 1-BCP6R
Date of Inspection: July 21, 2014
Site Number: 260008684
Inspected By: Mark Bailey

The primary focus of this inspection was to confirm compliance with Ministry of the Environment legislation and control documents, as well as conformance with Ministry drinking water related policies for the inspection period. The Ministry has taken a multi-barrier approach in the inspection of this drinking water system focusing on the water source, treatment components, applicable distribution components, sampling and monitoring programs, and response to adverse water quality incidents.

The York Centre has completed all of the necessary requirements as outlined in the report completed by the Ministry of the Environment dated September 12th 2014. A copy of this report is on file.

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [*]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [*] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text" value="1"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [*] No []</p> <p>Number of Interested Authorities you report to: <input type="text" value="1"/></p>
<p>The York Centre 11225 Leslie St Richmond Hill Ont L4S 1N5</p>	



	<p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [*] No []</p>
--	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
The York Centre	260008684

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [*] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method Posted

Describe your Drinking-Water System

- Chlorine assisted Greensand iron filter, “ 12 x 52”
- Duplex 5 micron cartridge sediment filtration
- Duplex NFS ultraviolet disinfection units with UV intensity monitors and safety solenoid valves.
- 60,000 grain water softener for hot water only

List all water treatment chemicals used over this reporting period

Chlorine assisted manganese greensand

Were any significant expenses incurred to?

- Install required equipment NO
- Repair required equipment Yes
- Replace required equipment NO



Please provide a brief description and a breakdown of monetary expenses incurred

Approximately \$5500.00 spent on water testing and regular maintenance completed by Neotec Water Treatment

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	12	0	0	12	0
Treated	12	0	0	12	0-1300
Distribution					

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	N/A	
Chlorine	4	0.25-0.71

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Carbon tetrachloide	July 29 2014	MAC 5	MDL 0.16	
Benzene	July 29 2014	MAC 5	MDL 0.32	
Chromium	July 30 2014	MAC 50	MDL 0.03	
*Lead	May 21 2013	MAC 10	MDL 0.02	DW 0.11
Mercury	July 30 2014	MAC 1	MDL 0.01	
Selenium	July 30 2014	MAC 10	MDL 1	
Sodium	July 30 2014	MAC 25	MDL. 0.2	



Uranium	July 30 2014	MAC 20	MDL 0.002	
Fluoride	July 30 2014	MAC 1.5	MDL 0.06	
Antimony	July 30 2014	MAC 6	MDL 0.02	
Arsenic	July 30 2014	MAC 25	MDL 0.2	
Barium	July 30 2014	MAC 1000	MDL 0.2	
Boron	July 30 2014	MAC 5000	MDL 0.2	
Cadmium	July 30 2014	MAC 5	MDL 0.003	

4 SAMPLES TAKEN May 12/15 Aug 18/15 Nov 9/15 March 7/2016				MDL 0.003-0.006 0.003-0.006 0.003-0.006 0.003-0.006
Nitrite				
Nitrate	MAC 10	5	1	0.013
Nitrate + Nitrite	MAC 10	5	1	0.013

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

Lead sample for May 21 2013 * Next Lead test required in May 2016

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	1	Mac 10 MDL 0.02	
Distribution			